



**Petition No. 1357 of 2018**

**BEFORE**

**THE UTTAR PRADESH ELECTRICITY REGULATORY COMMISSION**

**LUCKNOW**

**PRESENT:**

Hon'ble Sri Raj Pratap Singh, Chairman

Hon'ble Sri Suresh Kumar Agarwal, Member

Hon'ble Sri Kaushal Kishore Sharma, Member

**IN THE MATTER OF:** Seeking direction to M/s PPGCL to install two nos.765/ 400 KV, 1500 MVA ICTs at 3x660 MW Prayagraj Thermal Power project (Bara) as a contractual obligation under PPA.

1. UP Power Corporation Limited (through its Chairman), 7<sup>th</sup> Floor, Shakti Bhawan 14- Ashok Marg, Lucknow.
2. Paschimanchal Vidyut Vitran Nigam Ltd. (through its Managing Director), Urja Bhawan, Victoria Park, Meerut
3. Purvanchal Vidyut Vitran Nigam Ltd. (through its Managing Director) Purvanchal Vidyut Bhawan, P.O. Vidyut Nagar, DLW, Varanasi.
4. Madhyanchal Vidyut Vitran Nigam Ltd. (through its Managing Director), 4 Gokhale Marg, Lucknow.
5. Dakshinanchal Vidyut Vitran Nigam Ltd. (through its Managing Director) Urja Bhawan 220, K.V. Up-Sansthan Bypass Road Agra – 282007.
6. Kanpur Electricity Supply Co. Ltd., 14/71, Civil Lines, KESA House, Kanpur

..... **Petitioner**

AND

M/s Prayagraj Power Generation Co. Ltd.  
Through its Director  
P. O. Lohgara, Tahsil- Bara  
Distt- Prayagraj – 212107

..... **Respondents**

The following were present:

1. Sri Raghvendra Singh Advocate General, UP, UPPCL
2. Sri Sakya Singha Chaudhuri, Advocate, PPGCL
3. Ms Gayatri Aryan, Adv. PPGCL
4. Mohd Altaf Mansoor, Advocate, UPPCL



5. Sri Ashok Shukla Shukla, Authorised Representative, PPGCL
6. Sri Joginder Sindhvani, PPGCL
7. Sri Deepak Raizada, SE, UPPCL
8. Sri Rajiv Srivastava, Advocate, UPPCL
9. Sri. Armaan Grover, Counsel for Respondents (Prayagraj)
10. Sri. Ayush Singh EE, UPPCL
11. Sri. Gyanendra Yadav, AE, UPPCL

### ORDER

(Date of Hearing 07 February, 2019)

1. This case was last heard on 11.1.2019 and the order was passed on 06.02.2019.
2. In the hearing on 07.02.2019, The Commission asked the respondents that as per the Petition the respondents were under an obligation to put up 7 interconnecting transformers for exchange of power between the proposed 400KV and 765KV switchyard. The interconnected transformers would be of 500MVA, three phase auto transformers, 50HZ 765/400KV. This means that total capacity of interconnecting transformers was supposed to be of 3500MVA. This is also provided in TCE Consulting Engineers report attached with the RFP. As per CEA recommendations two nos. 1500MVA capacity 765/400 KV interconnecting transformers were to be installed at 3x360MW Bara Thermal Power Station. In such a situation how the respondents can wriggle out of their obligation by installing only one 1500MV 765/400 kV Interconnecting Transformer.
3. Sri SS Chowdhury, Advocate appearing on behalf of PPGCL stated that since it is a technical matter, he will have to seek instructions from his



---

client. The Commission asked the petitioner to file their written statement on this issue within two weeks after that the Commission will pass necessary orders on the petition either after holding another hearing or without that.

(Kaushal Kishore Sharma)  
Member

(Suresh Kumar Agarwal)  
Member

(Raj Pratap Singh)  
Chairman

Place: Lucknow

Dated: 11.02.2019